

Declaration of Conformity

In Accordance with ANSI/ISEA 125-2014



Alexander Andrew, Inc. 1306 S. Alameda St Compton, CA 90221

Declaration #

A0714007

Declaration Date

7.23.14

Tested Item #

7429SS

Permanent Roof Truss Anchor

Additional Items Conforming Under this Declaration:

7429SSK

Alexander Andrew, Inc. declares that the product(s) listed above is in conformity with the requirements of the following performance standard(s):

OSHA 1926.502

Conformity Assessment Method in accordance with ANSI/ISEA 125-2014

Level 1

Level 2

X

Level 3

Level 1: FallTech Lab
Outside the Scope of
ISO/IEC Standard 17025:2005

Level 2: FallTech Lab
Within the Scope of
ISO/IEC Standard 17025:2005

Level 3: Independent 3rd Party Lab
accredited to
ISO/IEC Standard 17025:2005

Supporting
Documentation

20140723-4

Authorized Signature

Name

Dustin Hawkins

Title

VP Business Development

Date

11.18.14

FallTech Test Report

Test Report Number	20140723-4	Date	7/23/2014	Rev	B	Rev Date	11/10/2014
Report Prepared For	FallTech						
Initiated By	Dan Redden	Test Specification	OSHA 1926.502 1926.502(d)(16)(v)				
Base Part #	7429SS	Description	Permanent Truss Anchor				
Proposed Part #	N/A	Built By Whom	Production	BOM	No		
Test Request #	None	Date Received		Date Complete	5/6/2014		
Test Operator	Dan Redden	Test Operator	N/A				

Material/Sample Identification

Sample ID	Description
None	Permanent Truss Anchor


Test Summary

Test Specification	Test Criteria	Test Result	Pass/Fail
OSHA 1926.502 1926.502(d)(16)(v)	Static Strength	Withstand 3,600 Lbf Load (2X Potential Impact Energy of 1800 Lbf) 3,811 Lbf	Pass

Conclusion

FallTech P/N 7429SS Permanent Truss Anchor meets the requirements of OSHA 1926.502.

Report Signatories and Approval

Lab Quality Manager Soung Liew		Date	7/25/2014
Witnessed by	Not Applicable	Date	Not Applicable

Rev A	Change P/N from 865 to 7429SS
Rev B	Created Digital Copy

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to the joint ISO-ILAC-IAF Communiqué dated January 2009).